

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX: +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382 E-mail: erda@erda.org

Web : http://www.erda.org



TEST REPORT

	SHEET 1 OF 9		
NAME & ADDRESS OF CUSTOMER	REPORT NO.: RP-1617-041701		
	DATE: 13.12.2016		
SUPREME ELECTRICALS PRIVATE LIMITED	CUSTOMER REF. No.:	DATED:	
F-409 (b), Road No. 14,	Nil	17.10.2016	
V.K.I. Area,	DATE OF SAMPLE	DATE OF	
Jaipur-302013	RECEIPT:	TESTING:	
	19.10.2016	24.10.2016 to	
	19.10.2016	21.11.2016	
SAMPLE DESCRIPTION	SAMPLE IDENTIFICATION		
100 kVA Distribution Transformer	ERDA SAMPLE CODE N	10.:	
	į E	ERDA-00164567	
11000/433 Volts, 5.25/133.34 Amp.,			
	SERIAL NO.: 25499		
Oil filled, 3 Star,			
	DRAWING NO.:		
Vector Group: Dyn-11,	NP/100/0		
	100/OL/3ST/		
ENERGY EFFICIENCY LEVEL: 1	100/CC/3STA	AR/2	
Further details as you shout No. 3 of O	WEAD OF MEG - 2016		
Further details as per sheet No. 3 of 9.	YEAR OF MFG.: 2016		
TEST DETAILS	TEST SPECIFICATION	EEE.	
Short-circuit withstand test	IS 1180 (Part 1): 2014		

(Cl. No. 17 & 21.3 c)

ENCLOSURES:

Number of oscillograms

: Eleven

Number of photograph

: One

Number of test circuit diagram : One

Number of drawings

: Three

REMARKS: The sample conforms to the requirements of standard for Short-circuit withstand test.

PREPARED BY

CHECKED BY

APPROVED BY J. R. Tahilwani

NOTE: 1. This report relates only to the particular sample received for testing in good condition at ERDA.

2. This report cannot be reproduced in part under any circumstances.

3. Publication of this report requires prior permission in writing from Director, ERDA.

4. Only test asked for by customer have been carried out.

5. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arised.

Caution: ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.



(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org
Web : http://www.erda.org

REPORT NO.: RP-1617-041701

DATE: 13.12.2016



SHEET 2 OF 9

	Contents		
1.	Technical specifications of test object assigned by customer	Sheet No. 3 of 9	
2.	Routine test results before short circuit	Sheet No. 4 of 9 to 5 of 9	
3.	Short-circuit withstand test	Sheet No. 6 of 9 to 7 of 9	
4.	Routine test results after short circuit	Sheet No. 8 of 9 to 9 of 9	
5.	Oscillogram No.	1162/01 to 1162/11	
6.	Photograph No.	1617-012538/1004	
7.	Test circuit diagram No.	OLSC/DTC/01	
8.	Drawing No.	NP/100/01 100/OL/3STAR/1 100/CC/3STAR/2	

PREPARED BY

CHECKED BY



IE 2081832



(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX: +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382 E-mail : erda@erda.org

Web : http://www.erda.org

REPORT NO.: RP-1617-041701

DATE: 13.12.2016



SHEET 3 OF 9

TECHNICAL SPECIFICATIONS OF TEST OBJECT ASSIGNED BY CUSTOMER

1. Name of manufacturer : SUPREME ELECTRICALS PRIVATE

LIMITED

2. Equipment : 100 kVA Distribution Transformer

3. Energy efficiency level : 1

4. Standard No. : (Cl. No. 17 & 21.3 c) of IS 1180 (Part 1): 2014

5. Serial No. : 25499

6. Type : Outdoor, Oil Cooled, 3 Star

7. kVA rating : 100 8. Rated voltage H.V. (Volts) : 11000 L.V. (Volts) : 433

9. Rated current H.V. (Amp.) : 5.25

L.V. (Amp.) : 133.34 10. Number of phases : 3

11. Connection H.V./L.V. : Delta/Star

12. Frequency (Hz.) : 50

13. Type of cooling: ONAN14. Temperature rise of oil: 35°C

15. Percentage Impedance : 4.5 % : DPC Aluminium wire, bare dia. 2.03mm

17. Secondary winding conductor : DPC Aluminium strip, bare size

(12mm x 3.2mm) x 3 Nos. in parallel

18. Quantity of oil (Litre): 21019. Weight of oil (kg.): 17220. Weight of core and winding (kg.): 347

21. Total weight (kg.) : 670
22. Vector group : Dyn-1

22. Vector group : Dyn-11
23. Year of manufacture : 2016

24. Insulation level H.V. : 28 kVrms 25. Insulation level L.V. : 3 kVrms

26. Total losses at 75°C (Watts) : 520 Max. (at 50 % load) : 1800 Max. (at 100 % load)

PREPARED BY

CHECKED BY



TE 2081831





(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33 : +91 (0265) 2638382 Fax

E-mail : erda@erda.org Web : http://www.erda.org





Sheet: 1 OF 34

TEST REPORT

ULR-TC538922000026954F

0LI 1033032200002033 II		0110001 1 01 01
NAME AND ADDRESS OF CUSTOMER	REPORT NO.: RP-2223-0)21713
Supreme electricals private limited.	DATE OF ISSUE: 08/10/	2022
F-409(B),Road No.14,V.K.I.Area,	CUSTOMER REF. NO.	DATED:
Jaipur-302013	Letter	12/07/2022
Rajasthan,	DATE OF SAMPLE	DATE OF
India.	RECEIPT:	TESTING:
	12/07/2022	04/08/2022 to
	13/07/2022	24/09/2022

SAMPLE DESCRIPTION

100 kVA Distribution Transformer (Non-Sealed type)

11000/433 Volts,

5.25/133.34 Amp.,

Oil filled, Vector Group: Dyn-11,

Energy efficiency level: 1

Further details as per sheet No. 3 OF 34.

TEST DETAILS

As per sheet 4 OF 34.

SAMPLE IDENTIFICATION

SAMPLE CODE: 828547/2022/SS/6

OR CODE: 100000039287

ENCODED SAMPLE CODE: 22E4084

SERIAL NO.: 52323

ERDA SERIAL NO.: ERDA-00474159

YEAR OF MFG.: 2022

TEST SPECIFICATIONS

As per sheet 4 OF 34.

ENCLOSURES: As per sheet 2 OF 34.

REMARKS: On respective sheets from 5 OF 34 to 33 OF 34.



PREPARED BY

APPROVED BY

Note: 1. This report relates only to the particular sample received for testing in good condition at E.R.D.A.

2. This report cannot be reproduced in part under any circumstances.

3. Publication of this report requires prior permission in writing from Director, E.R.D.A.

4. Only the tests asked for by the customer have been carried out.

5. Particulars of manufacturer/supplier, given in this report are based on information supplied by the customer, along with the test request/sample. ERDA does not assume any responsibility for the correctness of the information for above mentioned Sample under test (SUT). ERDA will not be responsible for any changes in SUT made after the test. This test report is given as per instrument status while testing.

6. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arised.

Caution: ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.







(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India. EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

: +91 (0265) 2638382 Fax : erda@erda.org E-mail Web : http://www.erda.org



ULR-TC538922000026954F

TEST REPORT NO: RP-2223-021713

DATE OF ISSUE: 08/10/2022

Sheet: 2 OF 34

Enclosures							
1.	. Oscillogram No.			0503/01 to 0503/11			
2.	Photograph No.			2223-004942/0531 As per sheet 34 OF 34			
3.	Test circuit diagram No.		OLSC/DTC/01				
4.	Drawing No.	Issue Status Revision	Date	Description			
	SE/RP/09	00	30.05.22	RATING AND DIAGRAM PLATE			
	SE/GA/09	00	30.05.22	OUTLINE GENERAL ARRANGEMENT DETAILS			
	SE/IC/09	00	30.05.22	CORE & COIL ASSEMBLY DETAILS			

PREPARED BY

CHECKED BY







(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

: +91 (0265) 2638382 : erda@erda.org E-mail Web : http://www.erda.org



Sheet: 3 OF 34

ULR-TC538922000026954F **REPORT NO:** RP-2223-021713

DATE OF ISSUE: 08/10/2022

TECHNICAL SPECIFICATIONS OF TEST OBJECT ASSIGNED BY CUSTOMER

1. Name of manufacturer : As mentioned on SHEET 1 OF 34 2. Equipment 1 100 kVA Distribution Transformer

3. Standard No. : As per customer's requirement,

> IS 2026, IS 1180 (Part 1): 2014 [Amendment No. 1, 2, 3 & 4]

4. Serial No. : 52323

5. Energy efficiency level : 1

6. Type : Outdoor, Oil filled, Non Sealed Type,

Aluminium wound, Amorphous core,

Non-Circular coil

7. kVA rating : 100

8. Rated voltage H.V. (Volts) : 11000

> L.V. (Volts) : 433

9. Rated current H.V. (Amp.) : 5.25

> L.V. (Amp.) : 133.34

10. Number of phases : 03

11. Connection H.V./L.V. : Delta/Star

12. Frequency (Hz.) : 50

13. Type of cooling : ONAN

14. Temperature rise of oil/winding : 35°C/40°C

15. Percentage Impedance : 4.50 %

16. Type of winding : Concentric

17. Primary winding conductor SE Aluminium wire, bare dia. 1.60mm

18. Secondary winding conductor : DPC Aluminium strip, bare size

 $(9.5 \text{mm} \times 3.5 \text{mm}) \times 3 \text{ Nos. in parallel}$

19. Quantity of oil (Liter) : 154

20. Weight of oil (kg.) : 128

21. Weight of core and winding (kg.) : 316

22. Total weight (kg.) : 604

23. Vector group : Dyn-11

24. Year of manufacture : 2022

25. Insulation level H.V. : 75 kVp / 28 kVrms

26. Insulation level L.V. : --- / 03 kVrms

27. Max. Total losses at 75°C (Watts) : 475 (at 50 % load)

28. Max. Total losses at 75°C (Watts) : 1650 (at 100 % load)



